Technician Daily Assignments

4/28/2017 4:39PM

Tech	Work Order	Customer / Special Instructions / Workorder Comments	Call Type / Problem / Contact	Scheduled Start Time	Priority / Time Slot	Est. Hours
96 - Jackie Moore						
	78754	7-Eleven # 35242 W. Seneca 1100 South Western Blvd West Seneca, NY14224	Retail non billable - 19516-6(DEC Audit Prep 7-Eleven Store W. Seneca (716) 809-7527			

MOBIL GET WORK ORDER SIGNED BY STORE
Prep site for DEC visit 5-2-17

Qty	Part #	Description	From	Time & Miles 96			
		Base		Depart:	8:38	Miles:	738
		7-Eleven W. Seneca		Arrive:	9:21	Miles:	784
				Depart:	10:46	Miles:	" "
				Arrive:		Miles:	
				Depart:		Miles:	
				Arrive:		Miles:	
	LUNCH			Depart:		Miles:	

☐ Core Returmed Complete: ☑ Incomplete: ☐ Follow-up Work Order: ☐

Site needs 1 reg 1 prem Tank Tag
Sumped out STP's (both) using sump pump.
Used shop vac to remove debris and water from both dispensors.

Customer Signature: [signature] Date: 5/1/2017

Franklin Fueling Systems

Sensor Status Report

Year 2017

7-Eleven West Seneca

Sensor	Name	Status	Last Updated
Liquid Sensor 1	IS REG	Ok	5/9/2017 1:44:24 PM
Liquid Sensor 2	IS SUPER	Ok	5/9/2017 1:44:24 PM
Liquid Sensor 1	IS REG	Ok	5/9/2017 12:35:18 PM
Liquid Sensor 2	IS SUPER	Ok	5/9/2017 12:35:18 PM
Liquid Sensor 1	IS REG	Ok	5/9/2017 10:34:20 AM
Liquid Sensor 2	IS SUPER	Ok	5/9/2017 10:34:20 AM
Liquid Sensor 1	IS REG	Ok	5/9/2017 8:35:22 AM
Liquid Sensor 2	IS SUPER	Ok	5/9/2017 8:35:22 AM
Liquid Sensor 1	IS REG	Ok	5/9/2017 6:34:22 AM
Liquid Sensor 2	IS SUPER	Ok	5/9/2017 6:34:22 AM
Liquid Sensor 1	IS REG	Ok	5/9/2017 4:44:27 AM
Liquid Sensor 2	IS SUPER	Ok	5/9/2017 4:44:27 AM
Liquid Sensor 1	IS REG	Ok	5/8/2017 10:34:16 PM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 10:34:16 PM
Liquid Sensor 1	IS REG	Ok	5/8/2017 8:34:21 PM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 8:34:21 PM
Liquid Sensor 1	IS REG	Ok	5/8/2017 6:34:20 PM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 6:34:20 PM
Liquid Sensor 1	IS REG	Ok	5/8/2017 4:34:18 PM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 4:34:18 PM
Liquid Sensor 1	IS REG	Ok	5/8/2017 1:44:22 PM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 1:44:22 PM
Liquid Sensor 1	IS REG	Ok	5/8/2017 12:35:19 PM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 12:35:19 PM
Liquid Sensor 1	IS REG	Ok	5/8/2017 10:34:24 AM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 10:34:24 AM
Liquid Sensor 1	IS REG	Ok	5/8/2017 8:35:25 AM

Copyright © 2004-2017 Franklin Fueling Systems. All rights reserved.

Sensor	Name	Status	Last Updated
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 8:35:25 AM
Liquid Sensor 1	IS REG	Ok	5/8/2017 6:34:22 AM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 6:34:22 AM
Liquid Sensor 1	IS REG	Ok	5/8/2017 4:44:43 AM
Liquid Sensor 2	IS SUPER	Ok	5/8/2017 4:44:43 AM
Liquid Sensor 1	IS REG	Ok	5/7/2017 10:34:24 PM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 10:34:24 PM
Liquid Sensor 1	IS REG	Ok	5/7/2017 8:34:17 PM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 8:34:17 PM
Liquid Sensor 1	IS REG	Ok	5/7/2017 6:34:19 PM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 6:34:19 PM
Liquid Sensor 1	IS REG	Ok	5/7/2017 4:34:27 PM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 4:34:27 PM
Liquid Sensor 1	IS REG	Ok	5/7/2017 1:44:25 PM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 1:44:25 PM
Liquid Sensor 1	IS REG	Ok	5/7/2017 12:35:22 PM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 12:35:22 PM
Liquid Sensor 1	IS REG	Ok	5/7/2017 10:34:27 AM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 10:34:27 AM
Liquid Sensor 1	IS REG	Ok	5/7/2017 8:35:18 AM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 8:35:18 AM
Liquid Sensor 1	IS REG	Ok	5/7/2017 6:34:14 AM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 6:34:14 AM
Liquid Sensor 1	IS REG	Ok	5/7/2017 4:44:40 AM
Liquid Sensor 2	IS SUPER	Ok	5/7/2017 4:44:40 AM
Liquid Sensor 1	IS REG	Ok	5/6/2017 10:34:29 PM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 10:34:29 PM
Liquid Sensor 1	IS REG	Ok	5/6/2017 8:34:30 PM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 8:34:30 PM
Liquid Sensor 1	IS REG	Ok	5/6/2017 6:34:25 PM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 6:34:25 PM

Copyright © 2004-2017 Franklin Fueling Systems. All rights reserved.

7-Eleven West Seneca

Sensor	Name	Status	Last Updated
Liquid Sensor 1	IS REG	Ok	5/6/2017 4:34:22 PM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 4:34:22 PM
Liquid Sensor 1	IS REG	Ok	5/6/2017 1:44:31 PM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 1:44:31 PM
Liquid Sensor 1	IS REG	Ok	5/6/2017 12:35:25 PM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 12:35:25 PM
Liquid Sensor 1	IS REG	Ok	5/6/2017 10:34:33 AM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 10:34:33 AM
Liquid Sensor 1	IS REG	Ok	5/6/2017 8:35:32 AM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 8:35:32 AM
Liquid Sensor 1	IS REG	Ok	5/6/2017 6:34:23 AM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 6:34:23 AM
Liquid Sensor 1	IS REG	Ok	5/6/2017 4:44:49 AM
Liquid Sensor 2	IS SUPER	Ok	5/6/2017 4:44:49 AM
Liquid Sensor 1	IS REG	Ok	5/5/2017 10:34:34 PM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 10:34:34 PM
Liquid Sensor 1	IS REG	Ok	5/5/2017 8:34:19 PM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 8:34:19 PM
Liquid Sensor 1	IS REG	Ok	5/5/2017 6:34:17 PM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 6:34:17 PM
Liquid Sensor 1	IS REG	Ok	5/5/2017 4:34:27 PM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 4:34:27 PM
Liquid Sensor 1	IS REG	Ok	5/5/2017 1:44:21 PM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 1:44:21 PM
Liquid Sensor 1	IS REG	Ok	5/5/2017 12:35:23 PM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 12:35:23 PM
Liquid Sensor 1	IS REG	Ok	5/5/2017 10:34:16 AM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 10:34:16 AM
Liquid Sensor 1	IS REG	Ok	5/5/2017 8:35:39 AM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 8:35:39 AM
Liquid Sensor 1	IS REG	Ok	5/5/2017 6:36:59 AM

Copyright © 2004-2017 Franklin Fueling Systems. All rights reserved.

7-Eleven West Seneca

Sensor	Name	Status	Last Updated
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 6:36:59 AM
Liquid Sensor 1	IS REG	Ok	5/5/2017 4:45:03 AM
Liquid Sensor 2	IS SUPER	Ok	5/5/2017 4:45:03 AM
Liquid Sensor 1	IS REG	Ok	5/4/2017 10:34:31 PM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 10:34:31 PM
Liquid Sensor 1	IS REG	Ok	5/4/2017 8:34:30 PM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 8:34:30 PM
Liquid Sensor 1	IS REG	Ok	5/4/2017 6:34:39 PM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 6:34:39 PM
Liquid Sensor 1	IS REG	Ok	5/4/2017 4:34:33 PM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 4:34:33 PM
Liquid Sensor 1	IS REG	Ok	5/4/2017 1:44:20 PM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 1:44:20 PM
Liquid Sensor 1	IS REG	Ok	5/4/2017 12:35:29 PM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 12:35:29 PM
Liquid Sensor 1	IS REG	Ok	5/4/2017 10:34:32 AM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 10:34:32 AM
Liquid Sensor 1	IS REG	Ok	5/4/2017 8:35:29 AM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 8:35:29 AM
Liquid Sensor 1	IS REG	Ok	5/4/2017 6:34:24 AM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 6:34:24 AM
Liquid Sensor 1	IS REG	Ok	5/4/2017 4:45:16 AM
Liquid Sensor 2	IS SUPER	Ok	5/4/2017 4:45:16 AM
Liquid Sensor 1	IS REG	Ok	5/3/2017 10:34:36 PM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 10:34:36 PM
Liquid Sensor 1	IS REG	Ok	5/3/2017 8:34:35 PM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 8:34:35 PM
Liquid Sensor 1	IS REG	Ok	5/3/2017 6:34:26 PM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 6:34:26 PM
Liquid Sensor 1	IS REG	Ok	5/3/2017 4:34:33 PM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 4:34:33 PM

Copyright © 2004-2017 Franklin Fueling Systems. All rights reserved.

7-Eleven West Seneca

Sensor	Name	Status	Last Updated
Liquid Sensor 1	IS REG	Ok	5/3/2017 1:44:39 PM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 1:44:39 PM
Liquid Sensor 1	IS REG	Ok	5/3/2017 12:35:41 PM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 12:35:41 PM
Liquid Sensor 1	IS REG	Ok	5/3/2017 10:34:37 AM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 10:34:37 AM
Liquid Sensor 1	IS REG	Ok	5/3/2017 8:35:32 AM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 8:35:32 AM
Liquid Sensor 1	IS REG	Ok	5/3/2017 6:34:21 AM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 6:34:21 AM
Liquid Sensor 1	IS REG	Ok	5/3/2017 4:44:42 AM
Liquid Sensor 2	IS SUPER	Ok	5/3/2017 4:44:42 AM
Liquid Sensor 1	IS REG	Ok	5/2/2017 10:34:30 PM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 10:34:30 PM
Liquid Sensor 1	IS REG	Ok	5/2/2017 8:34:44 PM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 8:34:44 PM
Liquid Sensor 1	IS REG	Ok	5/2/2017 6:34:27 PM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 6:34:27 PM
Liquid Sensor 1	IS REG	Ok	5/2/2017 4:34:26 PM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 4:34:26 PM
Liquid Sensor 1	IS REG	Ok	5/2/2017 1:44:25 PM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 1:44:25 PM
Liquid Sensor 1	IS REG	Ok	5/2/2017 12:35:53 PM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 12:35:53 PM
Liquid Sensor 1	IS REG	Ok	5/2/2017 10:34:24 AM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 10:34:24 AM
Liquid Sensor 1	IS REG	Ok	5/2/2017 8:35:16 AM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 8:35:16 AM
Liquid Sensor 1	IS REG	Ok	5/2/2017 6:34:15 AM
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 6:34:15 AM
Liquid Sensor 1	IS REG	Ok	5/2/2017 4:44:50 AM

Copyright © 2004-2017 Franklin Fueling Systems. All rights reserved.

7-Eleven West Seneca

Sensor	Name	Status	Last Updated
Liquid Sensor 2	IS SUPER	Ok	5/2/2017 4:44:50 AM
Liquid Sensor 1	IS REG	Ok	5/1/2017 10:34:18 PM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 10:34:18 PM
Liquid Sensor 1	IS REG	Ok	5/1/2017 8:34:16 PM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 8:34:16 PM
Liquid Sensor 1	IS REG	Ok	5/1/2017 6:34:14 PM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 6:34:14 PM
Liquid Sensor 1	IS REG	Ok	5/1/2017 4:34:15 PM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 4:34:15 PM
Liquid Sensor 1	IS REG	Ok	5/1/2017 1:44:13 PM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 1:44:13 PM
Liquid Sensor 1	IS REG	Ok	5/1/2017 12:35:18 PM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 12:35:18 PM
Liquid Sensor 1	IS REG	Ok	5/1/2017 10:34:20 AM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 10:34:20 AM
Liquid Sensor 1	IS REG	Ok	5/1/2017 8:35:14 AM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 8:35:14 AM
Liquid Sensor 1	IS REG	Ok	5/1/2017 6:34:10 AM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 6:34:10 AM
Liquid Sensor 1	IS REG	Ok	5/1/2017 4:44:21 AM
Liquid Sensor 2	IS SUPER	Ok	5/1/2017 4:44:21 AM
Liquid Sensor 1	IS REG	Ok	4/30/2017 10:34:22 PM
Liquid Sensor 2	IS SUPER	Ok	4/30/2017 10:34:22 PM
Liquid Sensor 1	IS REG	Ok	4/30/2017 8:34:19 PM
Liquid Sensor 2	IS SUPER	Ok	4/30/2017 8:34:19 PM
Liquid Sensor 1	IS REG	Ok	4/30/2017 6:34:17 PM
Liquid Sensor 2	IS SUPER	Ok	4/30/2017 6:34:17 PM
Liquid Sensor 1	IS REG	Ok	4/30/2017 4:34:17 PM
Liquid Sensor 2	IS SUPER	Ok	4/30/2017 4:34:17 PM
Liquid Sensor 1	IS REG	Ok	4/30/2017 1:44:15 PM
Liquid Sensor 2	IS SUPER	Ok	4/30/2017 1:44:15 PM

Copyright © 2004-2017 Franklin Fueling Systems. All rights reserved.

73608

ESTABROOKS
Systems & Training for the Petroleum Industry

EZY CHEK SYSTEMS
PRODUCT LINE TEST
FINAL REPORT

TEST DATE	7-20-16

Testing Company Information

Name	Reid Petroleum Corp.
Address	100 West Genesee St.
City	Lockport, NY, 14094
Phone	(716) 434-2885

Test Location Information

Name	7-Eleven #35242 W. Seneca
Address	1100 South Western Blvd.
City	West Seneca
Phone	(716) 809-7527
Contact	

Technican Information

Name	Thomas McOmber
Cert #	78-3704
Applied Pressure	50 PSI

PRODUCT LINE TEST
FINAL REPORT

	Product Type	Result
#1	Regular	Pass
#2	Super	Pass
#3		
#4		
#5		
#6		

Comments/Recommendations:

Systems & Training for the Petroleum Industry

EZY CHEK SYSTEMS
PRODUCT LINE TESTER
DATA SHEET

TEST DATE: 7-20-16

Testing Company Information

Name	Reid Petroleum corp.
Address	100 West Genesee St.
City	Lockport, NY, 14094
Phone	(716) 434-2895

Test Location Information

Name	7-Eleven #35242 W. Seneca
Address	1100 South western Blvd.
City	West Seneca
Phone	(716) 809-7527
Contact	

Technican Information

Name	Thomas M. Ombel
Cert #	78-3709

Applied Pressure: 50 PSI

#1 Product Type: Regular

TIME	DATA	-/+	GPL	RES	GPH
2:00	87	0	0.0037	0.0000	0.0000
2:15	87	0	0.0037	0	0
2:30	87	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		

FINAL RESULT: Pass

#2 Product Type: Super

TIME	DATA	-/+	GPL	RES	GPH
2:00	86	0	0.0037	0.0000	0.0000
2:15	86	0	0.0037	0	0
2:30	86	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		

FINAL RESULT: Pass

#3 Product Type:

TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

FINAL RESULT:

#4 Product Type:

TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

FINAL RESULT:

#5 Product Type:

TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

FINAL RESULT:

#6 Product Type:

TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

FINAL RESULT:

ESTABROOK'S
Systems & Training for the Petroleum Industry

EZY CHEK SYSTEMS
LEAK DETECTOR TESTER
DATA SHEET

TEST DATE 7/20/2016

Test Location Information	
Name	7-Eleven #35242 W. Seneca
Address	1100 South Western Blvd.
City	West Seneca
Phone	(716) 809-7527
Contact	

Testing Company Information	
Name	Reid Petroleum Corp.
Address	100 West Genesee St.
City	Lockport, NY, 14094
Phone	(716) 434-2885
Technician Information	
Name	Thomas McOmbet
Cert #	78-3709

TYPE OF LEAK DETECTOR

PUMP #	MAKE	MODEL	SERIAL #
1	Veeder-Root	FX1V	[redacted] 3023
2	Veeder-Root	FX1V	[redacted] 3022
3			
4			
5			
6			
7			
8			

PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	28	14	45	189ml	4Sec.	Pass
2	Super	28	13	50	189ml	2Sec.	Pass
3					189ml		
4					189ml		
5					189ml		
6					189ml		
7					189ml		
8					189ml		