

Table 1 - Summary of Results

Date	Atlantic Sample #	Layer	Diagram location number	Building area	Location (refer to diagrams)	Suspect material	Friability	Condition of Friable ACM	H.A.	Estimated Quantity of Homogeneous	
										ACM	% asbestos
9/17/16	I1716-201	n/a	1	2FL	Kitchen	White vinyl flooring (bottom)	Non-friable	n/a	A	n/a	NAD
9/17/16	I1716-202	n/a	2	2FL	Kitchen	White vinyl flooring (bottom)	Non-friable	n/a	A	n/a	NAD
9/17/16	I1716-203	n/a	3	2FL	Kitchen	12x12 P&S floor tile (top)	Non-friable	n/a	A	n/a	NAD
9/17/16	I1716-204	n/a	4	2FL	Kitchen	12x12 P&S floor tile (top)	Non-friable	n/a	A	n/a	NAD
9/17/16	I1716-205	n/a	5	2FL	Wall	Drywall	Friable	n/a	B	See loc. 39	Presumed
9/17/16	I1716-206	n/a	6	2FL	Foyer	Drywall	Friable	n/a	B		Presumed
9/17/16	I1716-207	n/a	7	2FL	R BR	Drywall	Friable	n/a	B		Presumed
9/17/16	I1716-208	n/a	8	2FL	Laundry	Joint compound	Friable	n/a	C		Presumed
9/17/16	I1716-209	n/a	9	2FL	Rear	Joint compound	Friable	n/a	C		Presumed
9/17/16	I1716-210	n/a	10	2FL	LR	Joint compound	Friable	n/a	C		Presumed
9/17/16	I1716-211	n/a	11	2FL	Hall	Plaster	Friable	n/a	D	n/a	NAD
9/17/16	I1716-212	n/a	12	2FL	Foyer	Plaster	Friable	n/a	D	n/a	NAD
9/17/16	I1716-213	n/a	13	2FL	R BR	Plaster	Friable	n/a	D	n/a	NAD
9/17/16	I1716-214	n/a	14	2FL	Kitchen	Textured ceiling	Friable	n/a	E	n/a	NAD
9/17/16	I1716-215	n/a	15	2FL	Kitchen	Textured ceiling	Friable	n/a	E	n/a	NAD
9/17/16	I1716-216	n/a	16	2FL	Wall	Loose fill insulation	Friable	n/a	F	n/a	NAD
9/17/16	I1716-217	n/a	17	2FL	Wall	Loose fill insulation	Friable	n/a	F	n/a	NAD
9/17/16	I1716-218	n/a	18	2FL	Rear register	Fabric duct wrap	Friable	Damaged	G	100 s.f.	57.1%
9/17/16	I1716-219	n/a	19	1FL	Front register	Fabric duct wrap	Friable	Damaged	G		PS
9/17/16	I1716-220	n/a	20	1FL	Side register	Fabric duct wrap	Friable	Damaged	G		PS
9/17/16	I1716-221	n/a	21	1FL	Front	Plaster	Friable	n/a	D	n/a	NAD
9/17/16	I1716-222	n/a	22	1FL	Front	Plaster	Friable	n/a	D	n/a	NAD
9/17/16	I1716-223	n/a	23	1FL	Vestibule	12x12 floor tile	Non-friable	n/a	H	n/a	NAD
9/17/16	I1716-224	n/a	24	1FL	Vestibule	12x12 floor tile	Non-friable	n/a	H	n/a	NAD
9/17/16	I1716-225	n/a	25	1FL	Rear BR closet	White vinyl flooring	Non-friable	n/a	I	25 s.f.	10.8%
9/17/16	I1716-226	n/a	26	1FL	Rear BR closet	White vinyl flooring	Non-friable	n/a	I		PS
9/17/16	I1716-227	n/a	27	1FL	LR closet	Yellow vinyl flooring	Non-friable	n/a	J	40 s.f.	12.9%
9/17/16	I1716-228	n/a	28	1FL	LR closet	Yellow vinyl flooring	Non-friable	n/a	J		PS

Table 1 Notes:

Orange highlighting indicates samples with greater than 1% asbestos - POSITIVE or presumed

NAD = No asbestos

PS = Positive Stop: the sample or layered system is presumed to contain asbestos

H.A. = Homogeneous Area